



Addendum #1

**Bid Opportunity: 5044 - St. Patrick CES Stage
Drapes**

Closing Date: Thursday, March 28, 2024 2:00 PM

Question 1:

Several curtain suppliers have requested specification for the curtain and related accessories. Please provide a specification so they can provide us with pricing.

Answer 1: Must meet the 2015 Ontario Fire Code Article 2.3.2.1. the curtains must meet the requirements of CAN/ULC-S109, “Flame Tests of Flame-Resistant Fabrics and Films” as specified in tender.

Please submit the specifications you are proposing including meeting the Can/ULC.