


## Bestco Estimating

---

**Sent:** May 29, 2024 2:53 PM  
**To:** Disabatino, Blaize  
**Subject:** CLARIFICATIONS: POST TENDER ADDENDUM #1: Tender 5066 Cathedral Classroom Additions  
**Attachments:** IMG\_2490.HEIC; IMG\_2495.HEIC

Good afternoon,  
Please see the following clarifications for Tender 5066.

1. Floor plan 1-A2.0 shows a new smart board in room 310A. Please provide a specification for this item.  
**Smart boards are NIC as they are by school.**
2. Please confirm the quantity of millwork items to be relocated under note D4 in room 310 / 310A.  
**There are 7 workstations in one location and 3 workstations in another. Each station is 3'x2' approximately. They share a common counter top which will need to be cut and exposed ends to be capped with laminate to match (as best as possible). These 10 stations will be relocated on the wall with the new smartboard as shown below. Also as noted below, new support gables will be required to provide to provide stability as new partition does not go to underside of deck above and therefor cannot be counted on to bear the weight of the workstations. The power and data raceways will also need to be modified to suit to provide same in the new location. Photos attached.**



- The electrical drawings do not identify voice, data or PA devices and integration. Please confirm that this will not be a requirement under the contract. If this is required, please advise who we should use to do this work.

**Please carry a \$5,000.00 cash allowance for this work.**

**Kindly confirm you have received this email.**

Thank you,

**Blaize DiSabatino** | Purchasing Analyst  
 Purchasing | Father Kennedy Catholic Education Centre




---

Sent: Monday, May 27, 2024 10:18 AM  
 To: >  
 Subject: POST TENDER ADDENDUM #1: Tender 5066 Cathedral Classroom Additions