

# Addendum #1

Whitehern Kitchenette

January 17<sup>th</sup>, 2025

1.

*Q: Please provide specifications for the millwork. Section 06200-Finished Carpentry does not appear to apply to this project.*

**A: MILLWORK IS TO COMPLY WITH SECTION 06200 – FINISHED CARPENTRY PART 1.4.1 (“FINISH CARPENTRY TO COMPLY WITH QUALITY STANDARDS FOR ARCHITECTURAL MILLWORK, EDITION 2, EXCEPT WHERE SPECIFIED OTHERWISE.”)**

**CABINET MATERIALS ARE AS SHOWN ON DRAWING SHEETS A102A, A102B & A103.**

**PRIMER AND PAINT FOR CABINETS IS SPECIFIED IN SPECIFICATION SECTION 09900 PAINTING.**

2.

*Q: Section 09210-Historic Plaster does not appear to apply to this project. Please advise if applicable and where scope is shown.*

**A: SECTION 09210 HISTORIC PLASTER IS INCLUDED TO PROVIDE STANDARDS FOR ANY “MAKE GOOD” WORK THAT IS REQUIRED, SHOULD EXISTING PLASTER FINISHES BE DAMAGED IN THE COURSE OF WORK.**

3.

*Q: Please provide detail of junction between new Resilient Flooring and existing quarter round and baseboard to remain.*

**A: REMOVE EXISTING QUARTER ROUND; LAY RESILIENT FLOORING TO FACE OF BASEBOARD; REINSTALL QUARTER ROUND OVER EDGE OF RESILIENT FLOORING.**

4.

*Q: Please advise if new Resilient Flooring is required under new millwork base cabinets.*

**A: CONTINUE RESILIENT FLOORING BENEATH NEW MILLWORK BASE CABINETS.**

5.

*Q: Section 09900 Painting, 3.5 Application: General Painting, Article .4 states: “Do not spray finishes or use rolls. Apply finishes using brushes only.” Please if paint finish by rolling is acceptable.*

**A: USE OF PAINT ROLLERS ON FLAT SURFACES IS ACCEPTABLE.**