

Royal Botanical Gardens Hall Interior Renos
680 Plains Road W, Burlington, Ontario
ADDENDUM NO. 1
2025.03.11

Page 1 of 21

The following additional instructions shall apply to and govern the tender documents.

AMENDMENT NO. 1 – ENGINEERED SPRINKLER DRAWINGS

- 1 Please find attached for your information only, **Engineered Sprinkler Drawings** for Royal Botanical Garden Auditorium/Hall. Sprinkler work to be done by Owner's Subtrade.

End of Addendum #1

This communication is intended as a private communication for the sole use of the primary addressee and those individuals listed for copies in the original message. The information contained in this communication is private and confidential and if you are not an original intended recipient you are hereby notified that copying, forwarding or other dissemination or distribution of this communication by any means is prohibited. If you are not specifically authorized to receive this communication and if you believe that you received it in error please notify the original sender immediately. This is proprietary to +VG Architects (The Ventin Group Ltd.)

50 Dalhousie Street, Brantford, Ontario N3T 2H8 | T: 519.754.1652 | F: 519.754.0830

72 Stafford Street, Suite 200, Toronto, Ontario M6J 2R8 | T: 416.588.6370 | F: 416.588.6327
1340 Wellington Street West, Ottawa, Ontario K1Y 3B7 | T: 613.680.5557

SPECIFICATIONS

1.0 GENERAL SPECIFICATIONS

1.1. THESE DRAWINGS ARE THE PROPERTY OF THE ENGINEERS AND SHALL NOT BE ALTERED WITHOUT APPROVAL. DRAWINGS SHALL BE RETURNED UPON REQUEST.

1.2. BEFORE SUBMITTING TENDER FOR THIS WORK, EXAMINE THE SITE, LOCAL SERVICES AND LOCAL CONDITIONS, MECHANICAL DRAWINGS, LOCATION OF EXISTING EQUIPMENT AND SPACE ALLOWANCES TO ASCERTAIN THAT THE WORK CAN BE SATISFACTORILY CARRIED OUT AS SHOWN ON THESE DRAWINGS AND AS HEREIN SPECIFIED. BEFORE COMMENCING WORK, EXAMINE THE WORK AND REPORT AT ONCE, ANY DEFECT OF INTERFERENCE AFFECTING THE WORK OF THIS SECTION OR THE GUARANTEE OF SAME. NO EXTRA WILL SUBSEQUENTLY BE ALLOWED TO COVER ANY THOROUGH INSPECTION OF THE GROUNDS, EXISTING CONDITIONS, DRAWINGS AND SPECIFICATION. CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS ON THE JOB AND REPORT DISCREPANCIES TO THE ENGINEER BEFORE PROCEEDING WITH THE WORK.

1.3. THESE DRAWINGS ARE FOR PERMIT, AND FOR PRICING, AND MUST BE ADHERED TO FOR INSTALLATION. IF CONTRACTOR WISHES TO ALTER DRAWINGS, THEN CONTRACTOR IS RESPONSIBLE FOR OBTAINING RE-APPROVALS.

1.4. CONTRACTOR TO SUPPLY AND INSTALL A COMPLETE AND FULLY OPERATIONAL AUTOMATIC SPRINKLER SYSTEM AS SHOWN ON THE DRAWINGS AND AS INDICATED IN THE SPECIFICATIONS AND CONFORMING TO N.F.P.A. REQUIREMENTS, O.B.C. REQUIREMENTS AND THE REQUIREMENTS OF THE LOCAL AUTHORITIES.

1.5. CONTRACTOR TO PROVIDE MONTHLY SUMMARY UPDATE OF AREAS OF WORK COMPLETED.

1.6. ALL WORK SHALL BE DONE IN ACCORDANCE WITH ALL CODES, STANDARDS BY-LAWS AND AUTHORITIES HAVING JURISDICTION.

1.7. SYSTEMS TO BE INSTALLED AS PER N.F.P.A. STANDARDS, AND LOCAL AUTHORITIES

1.8. ALL WORK SHALL CONFORM TO C.S.A., E.S.A. CODES, AND LOCAL, MUNICIPAL AND PROVINCIAL LAWS AND REGULATIONS.

1.9. SPRINKLER CONTRACTOR TO CO-ORDINATE INSTALLATION WITH EXISTING SITE CONDITIONS AND ACCEPT RESPONSIBILITY FOR AND COST OF MAKING ADJUSTMENTS TO PIPING TO AVOID INTERFERENCE WITH MECHANICAL, ELECTRICAL AND OTHER BUILDING COMPONENTS.

1.10. SPRINKLER CONTRACTOR TO INCLUDE FOR OFFSETS IN SPRINKLER PIPING AND MUST SUPPLY AND INSTALL TRAPEZE HANGERS WHERE REQUIRED. HANGERS FOR MAINS TO BE INSTALLED AT PANEL POINTS OF JOISTS.

1.11. ALL MATERIALS USED IN THE INSTALLATION OF THE SPRINKLER SYSTEM SHALL BE CANADIAN MADE, UNLESS SPECIFICALLY APPROVED IN WRITING PRIOR TO INSTALLATION BY THE ARCHITECTS AND/OR ENGINEERS RESPONSIBLE FOR THE SYSTEM DESIGN.

1.12. ALL SPRINKLERS SHALL BE U.L.C. LISTED AND SHALL BE THE TYPE AND TEMPERATURE RATING SPECIFIED ON THE DRAWINGS. SPRINKLERS OF SUITABLE TEMPERATURE RATING SHALL BE INSTALLED NEAR HEATING EQUIPMENT AS SPECIFIED IN N.F.P.A. STANDARD # 13 (LATEST EDITION).

1.13. CONTRACTOR TO ALLOW IN PRICE FOR SUFFICIENT PIPE AND FITTINGS TO INSTALL PENDENT SPRINKLERS WITHIN A 5 FT. RADIUS OF THE LOCATION SHOWN ON DRAWINGS.

1.14. PROVIDE SPARE SPRINKLER HEADS AND WRENCH IN A METAL CABINET, MOUNTED ON THE WALL NEAR THE MAIN SPRINKLER VALVE HEADER. AMOUNT AS PER N.F.P.A. STANDARD # 13.

1.15. UPON COMPLETION OF THE INSTALLATION, THE CONTRACTOR SHALL TEST THE SYSTEM AND SUBMIT TO THE ENGINEER COMPLETED CONTRACTORS TEST CERTIFICATES STATING THAT THE SYSTEMS HAVE BEEN INSTALLED, TESTED AND APPROVED BY THE AUTHORITIES HAVING JURISDICTION IN ACCORDANCE WITH N.F.P.A.#13, LATEST EDITION.

1.16. PENDENT SPRINKLERS INSTALLED WHERE SUSPENDED CEILING TILES OR DRYWALL OCCUR ARE TO BE EQUIPPED WITH TWO PIECE ESCUTCHEONS. (WHERE APPLICABLE)

1.17. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE INSTALLATION OF THE FIRE PROTECTION SYSTEMS AND FOR CO-ORDINATION WITH ALL SITE CONDITIONS. BEFORE COMMENCING WORK, EXAMINE THE SITE AND THE EXISTING CONDITIONS AND REPORT IMMEDIATELY TO THE ENGINEER ANY DEFECT OR INTERFERENCE AFFECTING THE COMPLETION OF THE WORK OR THE GUARANTEE OF THIS CONTRACTOR.

1.18. RECORD AS-BUILT DRAWINGS: BE RESPONSIBLE FOR CLEARLY MARKING, AS THE JOB PROGRESSES, ALL CHANGES AND DEVIATIONS FROM THE ROUTING OF SERVICES AND THE LOCATION OF EQUIPMENT SHOWN ON THE CONTRACT DOCUMENTS ON A BOUND SET OF WHITE PRINTS AVAILABLE AT THE SITE FOR PERIODIC INSPECTION THROUGHOUT THE DURATION OF THE WORK. NOTE THAT MARKED-UP WHITE PRINTS SHALL INCORPORATE ALL REVISIONS MADE BY CHANGE ORDERS, ADDENDA, FIELD INSTRUCTION, ETC. HAND THE AS-BUILT DRAWINGS TO THE ENGINEER AT THE END OF THE PROJECT.

1.19. THE DRAWINGS AND SPECIFICATIONS ARE INTENDED TO BE CO-OPERATIVE. PERFORM ALL WORK WHICH IS SHOWN, SPECIFIED OR REASONABLY IMPLIED ON THE DRAWINGS, BUT NOT MENTIONED IN THE SPECIFICATIONS OR VICE-VERSA, AS THOUGH FULLY COVERED BY BOTH.

1.20. WARRANT THE MECHANICAL WORK TO BE IN STRICT ACCORDANCE WITH THE CONTRACT DOCUMENTS AND FREE FROM DEFECTS FOR A PERIOD OF ONE (1) YEAR FROM THE DATE OF ISSUED OF CERTIFICATE OF SUBSTANTIAL PERFORMANCE OF THE WORK. PROVIDE EXTENDED WARRANTY WHERE SPECIFIED IN ALL SUBSEQUENT SECTIONS OF THE SPECIFICATION.

1.21. MAINTAIN LIABILITY INSURANCE WHICH WILL FULLY PROTECT THE OWNER AND THE CONTRACTORS FROM ANY AND ALL CLAIMS UNDER THE WORKPLACE SAFETY & INSURANCE BOARD ACT.

1.22. THE CONTRACTOR SHALL ASSUME FULL RESPONSIBILITY FOR THE LAYOUT OF WORK AND FOR ANY DAMAGE CAUSED TO THE PROPERTY OF THE OWNER OR OTHER TRADES THROUGH THE IMPROPER LOCATION OF MATERIALS, EQUIPMENT, OR CARRYING OUT OF THE WORK.

1.23. PROVIDE PIPE HANGERS OR SUPPORTS ON ALL PIPING. HANGER RODS MUST BE VERTICAL WITHOUT BENDS OR OFFSETS AND WORKMANSHIP MUST BE SUCH THAT FINISHED PIPING IS TRUE, BOTH WITH MANUFACTURER'S LINE AND GRADE. METAL STRAPS, WIRES, PERFORATED BANDS, CHAIN OR SOLID RING HANGERS USED AS PIPE HANGERS OR SUPPORTS WILL NOT BE ACCEPTABLE.

1.24. WHERE NEW PIPES PASS THROUGH EXISTING CONCRETE SLABS AND CONCRETE OR MASONRY WALLS, CORE DRILL OR SAW CUT AN OPENING. SIZE OPENINGS TO LEAVE 13 mm (1/2") CLEARANCES AROUND PIPES. PACK AND SEAL THE VOID BETWEEN THE OPENING AND THE PIPES FOR THE LENGTH OF THE OPENING WITH DOW CORNING SERIES 2000. "FIRESTOP" SEALANT U.L.C. APPROVED MATERIAL PACKED AND SECURED IN SUCH A MANNER THAT THE PACKING IN VERTICAL HOLES AND OPENINGS WILL NOT FALL OUT.

1.25. WHERE DISSIMILAR METALS ARE IN CLOSE PROXIMITY TO EACH OTHER, THEY SHALL BE SEPARATED BY MEANS OF WATERPROOF GASKETS OR OF APPROVED MATERIALS. SCREWS, BOLTS, RIVETS AND OTHER FASTENING DEVICES SHALL BE MADE OF THE SAME MATERIALS OR OF MATERIALS HAVING THE SAME CHARACTERISTICS AS THE METALS WHICH THEY FASTEN, IN ORDER TO PREVENT ELECTROLYTIC ACTION. PROVIDE HEAVY BRASS ADAPTORS FOR CONNECTIONS BETWEEN STEEL AND COPPER PIPES.

1.26. NO INSTALLATION SHALL BE CONCEALED OR RENDERED INACCESSIBLE BY DRYWALL, BOARDING OR OTHER BUILDING CONSTRUCTION, UNTIL IT HAS BEEN INSPECTED BY THE ENGINEER AND LOCAL AUTHORITIES HAVING JURISDICTION AND FOUND TO CONFORM TO CONTRACT DOCUMENT AND REGULATIONS. WHEN REQUESTING AN INSPECTION, THE CONTRACTOR SHALL PROVIDE A MINIMUM OF THREE (3) WORKING DAYS NOTICE IN ADVANCE.

1.27. DIMENSIONS AND/OR MEASUREMENTS INDICATED ON THE DRAWINGS ARE TO BE VERIFIED AT SITE AND ANY MAJOR DISCREPANCIES TO BE REPORTED PRIOR TO FABRICATION AND INSTALLATION. (IF APPLICABLE)

1.28. EXACT LOCATION AND ELEVATION OF MAINS TO BE DETERMINED BY CONTRACTOR TO SUIT SITE CONDITIONS.

1.29. CONTRACTOR TO CO-ORDINATE LOCATION OF SPRINKLERS WITH RESPECT TO SURFACE MOUNTED LIGHT FIXTURES AND MAINTAIN MINIMUM CLEARANCE AS REQUIRED BY NFPA 13 TO AVOID ANY OBSTRUCTION TO SPRAY PATTERN OF SPRINKLERS.

1.30. MINIMUM WALL THICKNESS OF SPRINKLER PIPING TO BE EQUIVALENT TO SCHEDULE 10S.

1.31. CONTRACTOR TO INCLUDE FOR AN ADDITIONAL 3 SPRINKLERS FOR BELOW OBSTRUCTIONS ETC.

1.32. SINCE THE BUILDING IS EXISTING, CONTRACTOR IS TO VISIT SITE AND BECOME FAMILIAR WITH EXISTING SITE CONDITIONS RELATIVE TO THE PROJECT AND REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO QUOTING OR FABRICATION

1.33. A COPY OF N.F.P.A STANDARD #25 IS TO BE PROVIDED AND LEFT IN A VISIBLE LOCATION IN THE SPRINKLER ROOM.

1.34. PROVIDE SHOP DRAWINGS FOR THE FOLLOWING: (WHERE APPLICABLE)


- A) - SPRINKLERS
B) - DOUBLE CHECK VALVE ASSEMBLY / BACKFLOW DEVICE
C) - RISER CHECK/ALARM VALVE AND TRIM/DRY PIPE VALVE
D) - SUPERVISORY DEVICES
E) - HANGERS

1.35. ALL SPRINKLER EQUIPMENT SHALL BE OF ONE MANUFACTURER FROM THE FOLLOWING:

- VICTAULIC
- VIKING
- TYCO
- RELIABLE
- OR APPROVED EQUAL. ALL SHALL BE U.L.C. LISTED FOR THEIR SPECIFIC APPLICATION.

1.36. CONTRACTOR MAY USE 1 INCH DIA. FLEXIBLE DROPS WITH A MAXIMUM LENGTH OF 4 FEET WITH A MAXIMUM OF 8, 90 DEGREE BENDS. FLEXIBLE PIPING IF USED IS TO BE STAINLESS STEEL WITH BRAIDED CONNECTION, SINGLE PIECE WELDED CONSTRUCTION WITH NO O-RINGS OR GASKETS, ULC LISTED AND FM APPROVED.

SITE PLAN



SCOPE OF WORK

SCOPE OF WORK:

- FIRE PROTECTION WORK CONSISTS OF MODIFYING EXISTING SPRINKLER SYSTEM THROUGHOUT THE RENOVATED GROUND FLOOR AUDITORIUM IN ACCORDANCE WITH DRAWINGS:

FP-01 - SITE PLAN, SPECIFICATIONS, DETAILS AND SPRINKLER HEADER DIAGRAM
FP-02 - PROPOSED SPRINKLER DESIGN LAYOUT - AUDITORIUM HIGH AND LOW CEILING

DESIGN DATA:

- ALL WORK AND MATERIALS SHALL BE INSTALLED IN ACCORDANCE WITH THE ONTARIO BUILDING CODE (2024), AUTHORITY HAVING JURISDICTION REQUIREMENTS, WITH NFPA 13 (2019)
- HYDRAULIC REQUIREMENTS ARE IN COMPLIANCE WITH NFPA 13 AND SPRINKLER HEAD SPECIFICATIONS.

CALCULATION #1 - WET SYSTEM - GROUND FLOOR - LIGHT HAZARD -
SPRK SYS DESIGNED FOR DISCHARGE RATE OF 0.1 GPM/SQ. FT OVER
AN AREA OF 1500 SQ. FT

CALCULATION #2 - WET SYSTEM - GROUND FLOOR - LIGHT HAZARD -
SPRK SYS DESIGNED FOR DISCHARGE RATE OF 0.1 GPM/SQ. FT WITH
A MAX OF 7 HEADS IN DESIGN AREA (19.3.3.4.2)


DESIGN CRITERIA:

AUDITORIUM DESIGNED AS WET TYPE SPRINKLER SYSTEM - LIGHT HAZARD - SPRINKLER SYSTEM IS DESIGNED TO DISCHARGE AT A DENSITY OF 0.10 GPM/SQ.FT OVER AN AREA OF 1500 SQ.FT PLUS 100 GPM FOR HOSES PER NFPA 13 (2019 ED, FIG 19.3.3.1.1, 19.3.3.2.5)


FIRE PUMP TEST INFORMATION:

FIRE PUMP TEST LOCATION: 680 PLAINS RD W, BURLINGTON ON
DATE: DECEMBER 11TH 2023
STATIC: 105 PSI
RESIDUAL: 88 PSI FLOW: 500 GPM

EXISTING SPRINKLER HEADER DETAILS



NFPA 13 DETAILS



SUBMITTALS

NO	DATE	DESCRIPTION	DWN	CH'D
1	FEB 28/2025	ISSUED FOR CLIENT REVIEW AND COORDINATION	TM	JC
2	MAR 10/2025	ISSUED FOR PERMIT	TM	JC



Norris Fire Consulting Inc

Smoke Control - Sprinkler - Fire Alarm - Code I

1840 Clements Road, Suite 202, Pickering, ON L1W 3Y2
Tel (905) 669-9154; www.norrisfireconsulting.com

Learn • Grow • Inspire • Execute



Professional Engineers
Ontario

Limited Engineering Licensee

Name: M B J Norris

Number: 100228627

Limitations: Specifying and reviewing of fire protection
and fire alarm systems as per OBC, OFC and NFPA
(13, 14, 17A, 20, 22, 24, 30, 70, 101, 2001 & 5000)

Association of Professional Engineers of Ontario

MAR. 10/25

AUDITORIUM A&B

680 PLAINS RD. W
BURLINGTON, ONTARIO

DRAWING TITLE


SITE PLAN, SPECIFICATIONS,
DETAILS AND SPRINKLER HEADER
DIAGRAM

JOB. NO. 24-0453

SCALE: 1 : 100

DRAWN BY: TM CHECKED BY: JC


SHEET FP-01



AUDITORIUM HIGH CEILING

SCALE 1:100

Hydraulic Calculation Data	
Design Area Number: 1	
Design Area Location: GROUND FLOOR HIGH CEILING	
Hazard/Occupancy: LIGHT HAZARD	
Design Density: 0.10 GPM / SQ FT	
Design Area: 1571 SQ FT	
Number of Sprinklers in Design Area: 18	
System Demand: 513.60 GPM	
System Pressure: 67.04 PSI	
Hose Allowance (Included): 100 GPM	



AUDITORIUM LOW CEILING

SCALE 1:100

Hydraulic Calculation Data	
Design Area Number: 2	
Design Area Location: GROUND FLOOR LOW CEILING	
Hazard/Occupancy: LIGHT HAZARD	
Design Density: 0.10 GPM / SQ FT	
Design Area: UP TO 7 HEADS PER LINE (19.3,3.4,2)	
Number of Sprinklers in Design Area: 9 (2 LINES)	
System Demand: 269.73 GPM	
System Pressure: 40.77 PSI	
Hose Allowance (Included): 100 GPM	

Table 10.2.7.1.2 Positioning of Sprinklers to Avoid Obstructions to Discharge (SSU/SSP)	
Distance from Sprinkler to Side of Obstruction (A)	Maximum Allowable Distance of Deflector above Bottom of Obstruction (B) [in.(mm)]
Less than 1 ft	0
1 ft to less than 1 ft 6 in.	2 1/2 (65)
1 ft 6 in. to less than 2 ft	3 1/2 (90)
2 ft to less than 2 ft 6 in.	5 1/2 (140)
2 ft 6 in. to less than 3 ft	7 1/2 (190)
3 ft to less than 3 ft 6 in.	9 1/2 (240)
3 ft 6 in. to less than 4 ft	12 (300)
4 ft to less than 4 ft 6 in.	14 (350)
4 ft 6 in. to less than 5 ft	16 1/2 (420)
5 ft to less than 5 ft 6 in.	18 (450)
5 ft 6 in. to less than 6 ft	20 (510)
6 ft to less than 6 ft 6 in.	24 (600)
6 ft 6 in. to less than 7 ft	30 (750)
7 ft to less than 7 ft 6 in.	35 (875)

FIGURE 10.2.7.1.2(a) Positioning of Sprinkler to Avoid Obstructions to Discharge (SSU/SSP)

ELEVATION VIEW

SPRINKLER OUTLET SIZES	
K2.8 TO 5.6: 3/4"	
K8.0 TO 16.8: 1"	
K22.4 TO 34: 1 1/4"	
DRY PEND & SW 1"	
ESFR DRY PEND 1 1/2"	

- GENERAL INSTALLATION NOTE:
- CONTRACTOR TO COORDINATE THE LOCATION OF PENDENT HEADS WITH ELECTRICAL & MECHANICAL SERVICES TO AVOID INTERFERENCE WITH OR OBSTRUCTIONS CREATED BY LIGHTS AND/OR DUCWORK (WHERE APPLICABLE).
 - CONTRACTOR TO CONFIRM EXISTING STRUCTURE AND PIPE ROUTING ON SITE PRIOR TO INSTALLATION
 - SPRINKLER CONTRACTOR TO INCLUDE FOR OFFSETS IN THE SPRINKLER PIPING AND SUPPLY AND INSTALLATION OF HANGERS. HANGERS SHALL BE PER NFPA 13.
 - ALL SPRINKLER HEADS IN DRYWALL CEILING TO BE OF CONCEALED HEAD TYPE SPRINKLERS

- LEGEND:
- EX --- EXISTING BRANCH LINE TO REMAIN
 - EX --- EXISTING MAIN TO REMAIN
 - NEW BRANCH LINE TO BE INSTALLED
 - NC NEW CONNECTION
 - RL EXISTING HEAD TO BE RELOCATED

SUBMITTALS

NO	DATE	DESCRIPTION	DWN	CHD
1	FEB 28/2025	ISSUED FOR CLIENT REVIEW AND COORDINATION	TM	JC
2	MAR 02/2025	ISSUED FOR PERMIT	TM	JC


HEAD COUNT

S/R=STANDARD RESPONSE Q/R=QUICK RESPONSE O C/W GUARD		
EXISTING PENDENT TO BE RELOCATED	-	
EXISTING STANDARD COVERAGE PENDENT (K=5.6) S/R TO REMAIN	-	
EXISTING STANDARD COVERAGE SIDEWALL (K=5.6) S/R TO REMAIN	-	
EXISTING STANDARD COVERAGE UPRIGHT (K=5.6) S/R TO REMAIN	-	
175F STANDARD COVERAGE UPRIGHT (K=5.6) S/R	2	
175F STANDARD COVERAGE PENDENT (K=5.6) S/R	30	



Norris Fire Consulting Inc
Smoke Control • Sprinkler • Fire Alarm • Code J
1840 Clements Road, Suite 202, Pickering, ON L1W 3Y2
Tel: (905) 669-9544; www.norrisfireconsulting.com
Learn • Grow • Inspire • Execute

PROJECT NORTH



Professional Engineers
Ontario
Limited Engineering Licensee
Name: M B J Norris
Number: 100229827
Limitations: Specifying and reviewing of fire protection and fire alarm systems as per OBC, OFC and NFPA (13, 14, 17A, 20, 22, 24, 30, 70, 101, 2001 & 5000)
Association of Professional Engineers of Ontario
MAR. 10/25

AUDITORIUM A&B

680 PLAINS RD. W
BURLINGTON, ONTARIO

DRAWING TITLE

PROPOSED SPRINKLER DESIGN
LAYOUT - AUDITORIUM HIGH AND LOW CEILING

JOB. NO. 24-0453

SCALE: 1 : 100

DRAWN BY: TM CHECKED BY: JC

SHEET FP-02

SPRINKLER SYSTEM HYDRAULICS FOR

680 PLAINS RD.



Professional Engineers
Ontario

Limited Engineering Licensee

Name: M B J Norris Mar. 10, 2025

Number: 100229827

Limitations: Specifying and reviewing of fire protection
and fire alarm systems as per OBC, OFC and NFPA
(13, 14, 17A, 20, 22, 24, 30, 70, 101, 2001 & 5000)

Association of Professional Engineers of Ontario



**680 PLAINS RD,
BURLINGTON, ON**
Date: MARCH 10TH, 2025


NORRIS FIRE CONSULTING INC

Project No. 24-0453

TABLE OF CONTENTS

<u>SECTION</u>	<u>SUBJECT</u>	<u>PAGES</u>
1	FIRE PUMP TEST	1
2	Remote Area #1 – Auditorium High Ceiling	8
3	Remote Area #2 – Auditorium Low Ceiling	7

Available Water Supply Graph



680 Plains Rd.

Burlington, ON

Test By

J.D. Collins Fire Protection Company

Test Date

December 11, 2023

Results

Pressure (PSI)	Flow (GPM)
105 PSI	0 GPM
88 PSI	500 GPM





Norris Fire Consulting INC.
1840 Clements Road
Suite 200
Pickering, On, L1W 3Y2
905-669-5154

Job Name : 24-0453 680 Plains Rd
Drawing : FP-02
Location : Burlington, On
Remote Area : 1
Contract : 24-0453
Data File : 24-0453 680 Plains Rd - Calc.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME 24-0453 680 Plains Rd
Location Burlington, On
Drawing # FP-02
Contract # 24-0453
Date 3/10/2025

DESIGN

Remote area # 1
Remote area location Auditorium High Ceiling
Occupancy classification LH
Density 0.1 - Gpm/SqFt
Area of application 1571 - SqFt
Coverage/sprinkler 150 - SqFt
Type of sprinkler calculated K5.6 Upright & Pendent S/R
Sprinklers calculated 18
In-rack demand - GPM
Hose streams 100 - GPM
Total water required (including hose streams) 381.733 - GPM @ 43.5382 - Psi
Type of system Wet
Volume of system (dry or pre-action) - Gal

WATER SUPPLY INFORMATION

Test date 12/11/2023
Location 680 Plains Rd.
Source of info Fire Pump Test

CONTRACTOR INFO Norris Fire Consulting INC.
Address 1840 Clements Road / Suite 200 / Pickering, On, L1W 3Y2
Phone # 905-669-5154
Name of designer
Authority having jurisdiction
NOTES:

text1(35) - invisible

Water Supply Curve

Norris Fire Consulting INC.
24-0453 680 Plains Rd


Page 2
Date 3/10/2025

City Water Supply:

C1 - Static Pressure : 105
C2 - Residual Pressure: 88
C2 - Residual Flow : 500

Demand:

D1 - Elevation : 11.044
D2 - System Flow : 413.422
D2 - System Pressure : 67.023
Hose (Demand) : 100
D3 - System Demand : 513.422
Safety Margin : 20.124



Fittings Used Summary

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 3
Date 3/10/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Avc	Alarm Vic 751	0	0	0	0	3	9	8	17	0	21	0	22	50	0	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 4
Date 3/10/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
FPO	105.0	88	500.0	87.146	513.42	67.023

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
SH	20.0	5.6	10.8	18.4	0.1	184
SH1	25.5		11.98			
SL	20.0	5.6	7.0	14.82	0.1	75
SL1	25.5		7.01			
H1	25.5	5.6	14.84	21.58	0.1	75
H2	25.5	5.6	17.55	23.46	0.1	83.8
H3	25.5	5.6	19.08	24.46	0.1	66.65
H4	25.5	5.6	22.49	26.56	0.1	66.65
H5	25.5	5.6	24.86	27.92	0.1	83.74
H6	25.5	5.6	10.63	18.26	0.1	154.98
H7	25.5	5.6	12.18	19.54	0.1	112.2
H8	25.5	5.32	11.98	18.4	K=K @ SH1	
L1	25.5		13.15			
H9	25.5	5.6	13.42	20.52	0.1	112.2
H10	25.5	5.32	16.26	21.43	K=K @ SH1	
L2	25.5		17.16			
H11	25.5	5.6	17.75	23.6	0.1	154.98
H12	25.5	5.6	22.31	26.45	0.1	106.25
H13	25.5	5.6	16.07	22.45	0.1	112.2
H14	25.5	5.6	16.49	22.74	0.1	154.98
H15	25.5	5.32	15.84	21.15	K=K @ SH1	
L3	25.5		16.62			
H16	25.5	5.32	18.32	22.75	K=K @ SH1	
L4	25.5		19.18			
H17	25.5	5.6	19.72	24.87	0.1	154.98
H18	25.5	5.6	23.74	27.29	0.1	106.25
M1	25.5		33.67			
M2	25.5		33.92			
M3	25.5		34.97			
M4	10.0		52.32			
M5	10.0		57.82			
M6	10.0		58.99			
M7	10.0		60.24			
TOR	10.0		61.57			
BOR	0.0		66.43			
FPO	0.0		67.02	100.0		

Final Calculations : Hazen-Williams

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 5
Date 3/10/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SH to SH1	20 25.500	5.60	18.40 18.4	1 1.049		32.000 32.000	120 0.1115	10.796 -2.382 3.569		Vel = 6.83	
SH1			0.0 18.40					11.983		K Factor = 5.32	
SL to SL1	20 25.500	5.60	14.82 14.82	1 1.049		32.000 32.000	120 0.0747	7.000 -2.382 2.390		Vel = 5.50	
SL1			0.0 14.82					7.008		K Factor = 5.60	
H1 to H2	25.500 25.500	5.60	21.58 21.58	1 1.049	2E 4.0	14.060 4.000 18.060	120 0.1497	14.845 0.0 2.704		Vel = 8.01	
H2 to H3	25.500 25.500	5.60	23.46 45.04	1.25 1.38		9.960 9.960	120 0.1536	17.549 0.0 1.530		Vel = 9.66	
H3 to H4	25.500 25.500	5.60	24.46 69.5	1.25 1.38		9.960 9.960	120 0.3429	19.079 0.0 3.415		Vel = 14.91	
H4 to H5	25.500 25.500	5.60	26.56 96.06	1.5 1.61		8.030 8.030	120 0.2945	22.494 0.0 2.365		Vel = 15.14	
H5 to M1	25.500 25.500	5.60	27.92 123.98	1.5 1.61	T 8.0	10.670 8.000 18.670	120 0.4721	24.859 0.0 8.815		Vel = 19.54	
M1			0.0 123.98					33.674		K Factor = 21.37	
H6 to H7	25.500 25.500	5.60	18.26 18.26	1 1.049		14.060 14.060	120 0.1100	10.634 0.0 1.546		Vel = 6.78	
H7 to L1	25.500 25.500	5.60	19.55 37.81	1.25 1.38		8.750 8.750	120 0.1112	12.180 0.0 0.973		Vel = 8.11	
L1			0.0 37.81					13.153		K Factor = 10.43	
H8 to L1	25.500 25.500	5.32	18.40 18.4	1 1.049	E T 2.0 5.0	3.490 7.000 10.490	120 0.1115	11.983 0.0 1.170		K = K @ SH1 Vel = 6.83	
L1 to H9	25.500 25.500		37.81 56.21	1.25 1.38		1.167 1.167	120 0.2314	13.153 0.0 0.270		Vel = 12.06	
H9 to L2	25.500 25.500	5.60	20.51 76.72	1.25 1.38		9.083 9.083	120 0.4116	13.423 0.0 3.739		Vel = 16.46	
L2			0.0 76.72					17.162		K Factor = 18.52	
H10 to L2	25.500 25.500	5.32	21.43 21.43	1 1.049	E 2.0	4.120 2.000 6.120	120 0.1479	16.257 0.0 0.905		K = K @ SH1 Vel = 7.96	

Final Calculations : Hazen-Williams

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 6
Date 3/10/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
L2 to H11	25.500 25.500		76.72 98.15	1.25 1.38			0.910 0.910	120 0.6495	17.162 0.0 0.591		Vel = 21.05	
H11 to H12	25.500 25.500	5.60	23.60 121.75	1.5 1.61			9.970 9.970	120 0.4566	17.753 0.0 4.552		Vel = 19.19	
H12 to M2	25.500 25.500	5.60	26.45 148.2	1.5 1.61	T	8.0	9.680 8.000 17.680	120 0.6568	22.305 0.0 11.613		Vel = 23.36	
M2			0.0 148.20						33.918		K Factor = 25.45	
H13 to H14	25.500 25.500	5.60	22.45 22.45	1.25 1.38			9.960 9.960	120 0.0424	16.071 0.0 0.422		Vel = 4.82	
H14 to L3	25.500 25.500	5.60	22.74 45.19	1.25 1.38			0.820 0.820	120 0.1549	16.493 0.0 0.127		Vel = 9.69	
L3			0.0 45.19						16.620		K Factor = 11.08	
H15 to L3	25.500 25.500	5.32	21.15 21.15	1 1.049	E	2.0	3.420 2.000 5.420	120 0.1445	15.837 0.0 0.783		K = K @ SH1 Vel = 7.85	
L3 to L4	25.500 25.500		45.20 66.35	1.25 1.38			8.150 8.150	120 0.3146	16.620 0.0 2.564		Vel = 14.23	
L4			0.0 66.35						19.184		K Factor = 15.15	
H16 to L4	25.500 25.500	5.32	22.75 22.75	1 1.049	E	2.0	3.240 2.000 5.240	120 0.1651	18.319 0.0 0.865		K = K @ SH1 Vel = 8.45	
L4 to H17	25.500 25.500		66.35 89.1	1.25 1.38			0.980 0.980	120 0.5429	19.184 0.0 0.532		Vel = 19.11	
H17 to H18	25.500 25.500	5.60	24.86 113.96	1.5 1.61			9.970 9.970	120 0.4040	19.716 0.0 4.028		Vel = 17.96	
H18 to M3	25.500 25.500	5.60	27.29 141.25	1.5 1.61	T	8.0	10.670 8.000 18.670	120 0.6010	23.744 0.0 11.221		Vel = 22.26	
M3			0.0 141.25						34.965		K Factor = 23.89	
M1 to M2	25.500 25.500		123.98 123.98	3 3.068			11.960 11.960	120 0.0204	33.674 0.0 0.244		Vel = 5.38	
M2 to M3	25.500 25.500		148.19 272.17	3 3.068			11.960 11.960	120 0.0875	33.918 0.0 1.047		Vel = 11.81	

Final Calculations : Hazen-Williams

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 7
Date 3/10/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M3 to M4	25.500 10		141.25 413.42	3 3.068	E 7.0	49.110 7.000 56.110	120 0.1897	34.965 6.713 10.642		Vel = 17.94	
M4 to M5	10 10		0.0 413.42	3 3.068	2E 14.0	15.000 14.000 29.000	120 0.1897	52.320 0.0 5.501		Vel = 17.94	
M5 to M6	10 10		0.0 413.42	3 3.068		6.140 6.140	120 0.1896	57.821 0.0 1.164		Vel = 17.94	
M6 to M7	10 10		0.0 413.42	4 4.026	T 20.0	4.890 20.000 24.890	120 0.0505	58.985 0.0 1.257		Vel = 10.42	
M7 to TOR	10 10		0.0 413.42	4 4.026		26.350 26.350	120 0.0505	60.242 0.0 1.331		Vel = 10.42	
TOR			0.0 413.42					61.573		K Factor = 52.69	
TOR to BOR	10 0		413.42	6 6.065	E T Avc 22.0	10.000 66.000 76.000	120 0.0069	61.573 4.331 0.521		Vel = 4.59	
BOR to FPO	0 0		0.0 413.42	6 6.065	T 3E 42.0	15.000 72.000 87.000	120 0.0069	66.425 0.0 0.598		Vel = 4.59	
FPO			100.00 513.42					67.023		Qa = 100.00 K Factor = 62.71	



Norris Fire Consulting INC.
1840 Clements Road
Suite 200
Pickering, On, L1W 3Y2
905-669-5154

Job Name : 24-0453 680 Plains Rd
Drawing : FP-02
Location : Burlington, On
Remote Area : 2
Contract : 24-0453
Data File : 24-0453 680 Plains Rd - Calc New Main.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME 24-0453 680 Plains Rd
Location Burlington, On
Drawing # FP-02
Contract # 24-0453
Date 3/10/2025

DESIGN

Remote area # 2
Remote area location Auditorium Low Ceiling
Occupancy classification LH
Density 0.1 - Gpm/SqFt
Area of application 1571 - SqFt
Coverage/sprinkler 150 - SqFt
Type of sprinkler calculated K5.6 Upright & Pendent S/R
Sprinklers calculated 9
In-rack demand - GPM
Hose streams 100 - GPM
Total water required (including hose streams) 381.733 - GPM @ 43.5382 - Psi
Type of system Wet
Volume of system (dry or pre-action) - Gal

WATER SUPPLY INFORMATION

Test date 12/11/2023
Location 680 Plains Rd.
Source of info Fire Pump Test

CONTRACTOR INFO Norris Fire Consulting INC.
Address 1840 Clements Road / Suite 200 / Pickering, On, L1W 3Y2
Phone # 905-669-5154
Name of designer
Authority having jurisdiction
NOTES:

text1(35) - invisible

Water Supply Curve

Norris Fire Consulting INC.
24-0453 680 Plains Rd


Page 2
Date 3/10/2025

City Water Supply:

C1 - Static Pressure : 105
C2 - Residual Pressure: 88
C2 - Residual Flow : 500

Demand:

D1 - Elevation : 3.176
D2 - System Flow : 169.734
D2 - System Pressure : 40.768
Hose (Demand) : 100
D3 - System Demand : 269.734
Safety Margin : 58.805



Fittings Used Summary

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 3
Date 3/10/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Avc	Alarm Vic 751	0	0	0	0	3	9	8	17	0	21	0	22	50	0	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 4
Date 3/10/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
FPO	105.0	88	500.0	99.573	269.73	40.768

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
SH	20.0	5.6	10.8	18.4	0.1	184
SH1	25.5		11.98			
SL	20.0	5.6	7.0	14.82	0.1	75
SL1	25.5		7.01			
H19	7.333	5.6	8.45	16.28	0.1	75
H20	7.333	5.6	8.61	16.43	0.1	83.8
H21	7.333	5.6	9.33	17.11	0.1	66.65
H22	7.333	5.6	11.0	18.57	0.1	66.65
H23	7.333	5.6	7.25	15.08	0.1	66.65
H24	7.333	5.6	7.0	14.82	0.1	66.65
L5	7.333	5.6	7.28	15.11	0.1	66.65
H25	7.333	5.6	8.42	16.25	0.1	66.65
H26	7.333	5.6	10.96	18.54	0.1	66.65
H27	7.333	5.6	14.8	21.54	0.1	66.65
M8	7.333		15.71			
M9	7.33		17.12			
M10	25.5		19.74			
M1	25.5		24.8			
M2	25.5		25.24			
M3	25.5		25.68			
M4	10.0		34.44			
M5	10.0		35.5			
M6	10.0		35.72			
M7	10.0		35.96			
TOR	10.0		36.22			
BOR	0.0		40.65			
FPO	0.0		40.77	100.0		

Final Calculations : Hazen-Williams

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 5
Date 3/10/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SH to SH1	20 25.500	5.60	18.40 18.4	1 1.049		32.000 32.000	120 0.1115	10.796 -2.382 3.569		Vel = 6.83	
SH1			0.0 18.40					11.983		K Factor = 5.32	
SL to SL1	20 25.500	5.60	14.82 14.82	1 1.049		32.000 32.000	120 0.0747	7.000 -2.382 2.390		Vel = 5.50	
SL1			0.0 14.82					7.008		K Factor = 5.60	
H19 to H20	7.333 7.333	5.60	16.28 16.28	1.25 1.38		6.833 6.833	120 0.0234	8.450 0.0 0.160		Vel = 3.49	
H20 to H21	7.333 7.333	5.60	16.43 32.71	1.25 1.38		8.500 8.500	120 0.0849	8.610 0.0 0.722		Vel = 7.02	
H21 to H22	7.333 7.333	5.60	17.11 49.82	1.25 1.38		9.000 9.000	120 0.1852	9.332 0.0 1.667		Vel = 10.69	
H22 to M8	7.333 7.333	5.60	18.57 68.39	1.25 1.38		14.167 14.167	120 0.3328	10.999 0.0 4.715		Vel = 14.67	
M8			0.0 68.39					15.714		K Factor = 17.25	
H23 to L5	7.333 7.333	5.60	15.08 15.08	1.25 1.38		1.500 1.500	120 0.0207	7.254 0.0 0.031		Vel = 3.23	
L5			0.0 15.08					7.285		K Factor = 5.59	
H24 to L5	7.333 7.333	5.60	14.82 14.82	1.25 1.38	E T	5.500 9.000 14.500	120 0.0197	7.000 0.0 0.285		Vel = 3.18	
L5 to H25	7.333 7.333	5.60	30.19 45.01	1.25 1.38		7.417 7.417	120 0.1534	7.285 0.0 1.138		Vel = 9.65	
H25 to H26	7.333 7.333	5.60	16.26 61.27	1.25 1.38		9.333 9.333	120 0.2716	8.423 0.0 2.535		Vel = 13.14	
H26 to H27	7.333 7.333	5.60	18.53 79.8	1.25 1.38		8.667 8.667	120 0.4427	10.958 0.0 3.837		Vel = 17.12	
H27 to M8	7.333 7.333	5.60	21.54 101.34	1.25 1.38		1.333 1.333	120 0.6894	14.795 0.0 0.919		Vel = 21.74	
M8			0.0 101.34					15.714		K Factor = 25.56	
M8 to M9	7.333 7.330		169.73 169.73	1.5 1.61		1.667 1.667	120 0.8440	15.714 0.001 1.407		Vel = 26.75	

Final Calculations : Hazen-Williams

Norris Fire Consulting INC.
24-0453 680 Plains Rd

Page 6
Date 3/10/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M9 to M10	7.330 25.500		0.0 169.73	1.5 1.61			12.417 12.417	120 0.8442	17.122 -7.869 10.483		Vel = 26.75	
M10 to M1	25.500 25.500		0.0 169.73	1.5 1.61			6.000 6.000	120 0.8443	19.736 0.0 5.066		Vel = 26.75	
M1 to M2	25.500 25.500		0.0 169.73	3 3.068			11.960 11.960	120 0.0365	24.802 0.0 0.437		Vel = 7.37	
M2 to M3	25.500 25.500		0.0 169.73	3 3.068			11.960 11.960	120 0.0365	25.239 0.0 0.437		Vel = 7.37	
M3 to M4	25.500 10		0.0 169.73	3 3.068	E	7.0	49.110 7.000 56.110	120 0.0365	25.676 6.713 2.050		Vel = 7.37	
M4 to M5	10 10		0.0 169.73	3 3.068	2E	14.0	15.000 14.000 29.000	120 0.0365	34.439 0.0 1.059		Vel = 7.37	
M5 to M6	10 10		0.0 169.73	3 3.068			6.140 6.140	120 0.0366	35.498 0.0 0.225		Vel = 7.37	
M6 to M7	10 10		0.0 169.73	4 4.026	T	20.0	4.890 20.000 24.890	120 0.0097	35.723 0.0 0.242		Vel = 4.28	
M7 to TOR	10 10		0.0 169.73	4 4.026			26.350 26.350	120 0.0097	35.965 0.0 0.256		Vel = 4.28	
TOR			0.0 169.73						36.221		K Factor = 28.20	
TOR to BOR	10 0		169.73	6 6.065	E T Avc	14.0 30.0 22.0	10.000 66.000 76.000	120 0.0013	36.221 4.331 0.101		Vel = 1.88	
BOR to FPO	0 0		0.0 169.73	6 6.065	T 3E	30.0 42.0	15.000 72.000 87.000	120 0.0013	40.653 0.0 0.115		Vel = 1.88	
FPO			100.00 269.73						40.768		Qa = 100.00 K Factor = 42.24	