

ADDENDUM No.01

Issue Date: May 2, 2025

WILFRID LAURIER UNIVERSITY
WLU-ART-E building Railing Project- Construction
Project Reference: 2021-PR-36.1
75 University Ave W, Waterloo, ON N2L 3C5

TO: ALL INVITED CONTRACTORS

Note: This Addendum forms part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of the Addendum by inserting its number and date on the Pricing Form. Failure to do so may subject proponent to disqualification.

CLARIFICATIONS:

Attached is addendum 01 issued by the consultant Architects Workshop (The addendum for the consultant Architects Workshop consists of a total of one pdf. page)

End of Addendum No. 01

WORKSHOP

Addendum 01


Project: Arts E Wing Railing - 75 University Ave
W, Waterloo, ON N2L 3C5

Date: 1 May 2025

Pages incl. cover: 1

Tender No. 2021-PR-36.1

The following changes, additions, deletions and clarifications are hereby made an integral part of the documents, including the drawings and specifications for the above project.

Item	Description
1.01	<p>Question: How are we to finish the existing terrazzo when the old railing is removed?</p> <p>Answer: Screw holes in face of terrazzo visible after install of new railing to be patched and made good with concrete repair mortar. Contractor to submit proposed product for consultant review prior to completing the work.</p> 
1.02	<p>Clarification: Asbestos abatement cost is not to be carried within the project bid. If asbestos is encountered during the project, the cost for abatement will be an extra to the project. The General Contractor will retain Zero Environmental (Randy Blazer) for any abatement work.</p>

End of Addendum 01